

WATER QUALITY TESTING REPORT

Name of Block : - Seppa
Name of School : - KAMENG PRESIDIUM SCHOOL
Name of source : - psp(School)
Date of Sample : - 30/06/2025
Date of Sample Tested : - 30/06/2025

Sl No	Name & Parameters	Range	Result
1.	Turbidity in	1-5 NTU	1
2.	PH	6.5-8.5	6.9
3.	Chloride	250mg/l	0.189
4.	Fluoride	1.5mg/l	0.112
5.	Hardness	0-200mg/l	1.5
6.	Iron	0.3 mg/l	0.0
7.	Alkalinity	0-600 mg/l	110
8.	Bacteriological Test	No relaxation	Negative


District Laboratory
PHE & WS Division
Seppa
Lab Assistant
PHE & WS Division
Seppa


Assistant Engineer
PHE & WS Sub-Division, Seppa
Assistant Engineer
PHE & Water Supply
Sub - Division, Seppa